arabtec

SUBMITTAL COVER SHEET

SECTOR 1

Contract No.	1505
Contract Title:	Main Construction Contract JBR01
Contractor:	**Arabtec Construction (LLC) JBR 01**

Submittal Type:	Sub Contractor Approval Request
Submittal No:	SCAR-00020
Revision No:	001
Revision Date:	23 Sep 2004
Title:	PQD for CBT Couplers / Cicon
Discipline:	Stru

Product Name:

Manufacturer: Bautech International

TO: Hyder Consulting Middle East Ltd

Contractor's Comments:

Test Report (Chemical Analysis) for CBT Couplers by Geoconsult.

arabtec JBR

NAME	ACTION	INFO
MEP		
PLAN		
QA	✓	
SAF		
DCC		
Saby		✓
Mark		✓

RETURN ORIGINAL TO DCC FOR FILING ✓

FILE NO:

Lead Sector Consultant's Comments:

1. Approval only for chemical test report.
2. Usage of couplers subject to satisfactory test reports for tensile strength. Please submit tensile test reports.

JBR - 1
arabtec 02 OCT 2004 5:00
RECEIVED

CONTRACTOR's REVIEW	SUBMITTAL REVIEW STATUS
Contractor has reviewed this submission prior to submission to Consultant. **Signature**_____	☐ A Approved No Comments ☑ B Approved As Noted ☐ C Not Approved - Revise
DATE RECEIVED BY CONSULTANT 23.09.04	**DATE RETURNED TO CONTRACTOR** 02.10.04

DESIGN CONSULTANT SIGNATURE

For and on behalf of
Hyder Consulting Middle East Ltd — pp George Larkins — 02.10.04 Date

Copy: **Mace International Ltd:**

Expedition ®
f_jbr_sb_01

JIBV