



THE PALM JUMEIRAH
CONTRACT NUMBER JAP006- C106
MIDDLE BRIDGES ON TRUNK

JAP006- C106
 22 JUN 2004
 9:40 AM
 Received
 NAKHEEL

DRAWING / DOCUMENT TRANSMITTAL FORM (DTF)

To: M/s NAKHEEL Ref. No.: JAP006/C106/L&T-NAK/T/090 (A)
 Attention: Mr. Tawfiq Ghazi, Project Manager (R & B) Date: 22/06/04
 First Submission Second Submission Further Submission Number

Previous Submittal Ref.: JAP006/C106/L&T-NAK/T/090 Date: 08/05/04 Previous Approval Category: C
 Relevant Specification Section / Contract Reference : Volume-3 / Part- 1 / Section-4

THIS SUBMITTAL INTENDED FOR
 APPROVAL / COMMENT YOUR INFORMATION / RECORDS
 PER YOUR REQUEST YOUR ACTION

Sr. No.	Document No.	Description	Rev.	Copies	Approval Category (NAKHEEL Use)
1	DR - 252187/1 DR - 252187/2	Laboratory test report of Mechanical Properties of Coupled reinforcement steel bar of 32mm dia (Piling Works)	-	1+3	

ARCHITECTURAL CIVIL / STRU ELECTRICAL MECHANICAL
 PLUMBING LANDSCAPING OTHER

FOR CONTRACTOR
 Name: Mr. R. Ethirajan, Signature *R. Ethirajan* Title: Project Manager Date: 22/06/04

NAKHEEL COMMENTS: Above said results of the couplers are satisfactory, failure is from the bar not from the coupler.
from 24/6.
Noted from 27/6/04
27/6

Approval Codes: **A** = Approved **B** = Approved with comments **C** = Incorporate comments **D** = Rejected
 Incorporate & Proceed resubmit before proceeding

FOR NAKHEEL
 Name: Signature Title: Date:

L&T - ECCD		
Palm Jumeirah Middle Bridge		
	ACTION	INF.
Plan	✓	
Accts.		
Exe.		
Others		✓

RECEIVED
 27 JUN 2004
 BY: *[Signature]*

[Signature]
 27/6