



NAKHEEL

# THE PALM JUMEIRAH SHORELINE APARTMENTS

Attention Mr. ALI EL-ORFALY

Transmittal No.: C02-000-0357-05210-00

CONTRACTOR NAME: Seidco General Contracting Co. L. L. C.

Date: Dec. 01, 2004

TRANSMISSION OF DOCUMENTS/TEST REPORTS/Samples

1. SUBMITTED FOR	CODE
APPROVAL	1
YOUR INFORMATION	2


RE: Shoreline Apartments - Package 2 CONTRACT NO. JAP006-400b

TO: TURNER  
CC: ACE

2. ACTION	
APPROVED	A
APPROVED WITH COMMENTS INCORPORATE COMMENTS	B
RESUBMIT BEFORE PROCEEDING	C
REJECTED	D
	E

WE ARE SENDING HERewith DOCUMENTS THAT COMPLIES WITH THE CONTRACT DOCUMENT

QTY	DRAWING, SPEC. OR DOC. REF.	ITEM SEQ NUMBER	DESCRIPTION	TYPE	CODE	
					Submittal	Action
2	Section 03210 - Steel Reinforcement	1	CBT Repair Coupler from Baute International - Sample Attached - 1 pc.	MD	1	B



COPIES

EET

PM (TCI)

ACE (ACE)

For CONTRACTOR

ACE/TCI to enter Action Codes and Remarks, and return to CONTRACTOR

REMARKS:

- NO OBJECTION ON THE PROPOSED STEEL COUPLER (CBT REPAIR COUPLER) FROM M/S BAUTECH INTERNATIONAL.
- SAMPLING SHALL BE CARRIED OUT ON THE PROPOSED PRODUCT AND TESTED IN ACCORDANCE WITH THE RELATIVE STANDARD BS 4449 AND IN COMPLIANCE WITH BS 8112-1:1997 CLAUSE 3.12.8.16.2

Contractor's compliance with the drawings and specifications of the drawings and specifications. This check is only for review of general compliance with the design of the project and general compliance with the information given in the contract documents. The Contractor is responsible for confirming and executing all quantities and methods of construction, coordinating the work with that of other trades, and performing the work in a safe and satisfactory manner.

COPIES TO

NAKHEEL

PM (TCI)

ACE (ACE)

For TURNER INTERNATIONAL  
DATE: 6/12/04

The Palm - Jumeirah Shoreline Apts. Office		
Date Recd. 04/10/04 - 9:27		
Dist	Action	Inte
MT	✓	✓
HJ	✓	
AG	✓	
Check 350-01		

11 Code to be entered by CONTRACTOR

12 Code to be entered by ACE (TCI)

C002-0357 Baute Intl. T Coupler

04-12-04

6/12/04

34