

## AL HABTOOR MURRAY & ROBERTS JOINT VENTURE TECHNICAL SUBMITTAL



<b>HMR 819</b>	OWNER : MAZYOOD GIGA INTERNATIONAL			
	CONSULTANT : W.S. ATKINS & PARTNERS OVERSEAS			
	PROJECT : GOLD CREST RESIDENTIAL TOWER - PLOT V2			
INITIATOR HMR - BTI	SUBCONTRACTOR REF. No. PQD/BICBT/027/04/05	DISCIPLINE STRUCTURAL	SUBMITTAL No. HMR-819-S-TS-087	REV. 0
<input checked="" type="checkbox"/> PRE-QUALIFICATION	<input type="checkbox"/> TECHNICAL DATA	<input checked="" type="checkbox"/> TEST REPORTS	<input type="checkbox"/> C.V.s	<input type="checkbox"/> OTHER
<input checked="" type="checkbox"/> APPROVAL		<input type="checkbox"/> INFORMATION	<input type="checkbox"/> RECORD	
<b>DOCUMENTS :</b>				
3 Sets of Pre-qualification documents for Threaded Couplers				
<b>DESCRIPTION :</b>				
Pre-qualification documents and Test Reports of Bautech International (L.L.C.) FOR Threaded Couplers				
INITIATOR : Bautech International (L.L.C)		SUBMITTED BY HMR : BAUTECH - INT'L		
SIGNATURE : _____		SIGNATURE : <i>Ibrahim Hayasat</i> Ibrahim Hayasat Project Manager		
APPROVAL SUBMITTAL DATE : 08-May-05		APPROVAL REQUIRED DATE : 15-May-05		
RECEIVED BY W.S. ATKINS : <i>[Signature]</i>		<div style="border: 1px solid black; padding: 5px; display: inline-block;"> <p style="margin: 0;"><b>RECEIVED</b></p> <p style="margin: 0;">- 9 MAY 2005</p> <p style="margin: 0;"><b>ATKINS</b></p> <p style="margin: 0;">DATE OFFICE</p> </div>		
APPROVAL STATUS : <input type="checkbox"/> Approved <input checked="" type="checkbox"/> Approved with Comments <input type="checkbox"/> Not Approved <input type="checkbox"/> Resubmit				
<b>CONSULTANT'S COMMENTS :</b>				
<p>16, 25 &amp; 32 Dia to be tested for tensile strength and yield strength and results to be submitted for final approval</p>				
<b>CONSULTANT'S APPROVAL :</b>				
SIGNATURE : <i>[Signature]</i>		DATE : 12/5/05		
Farouk H. Fathalla Resident Engineer				

**AL HABTOOR MURRAY & ROBERTS JOINT VENTURE**  
**DOCUMENT TRANSMITTAL**

<b>OWNER : MAZYOOD GIGA INTERNATIONAL</b> <b>CONSULTANT : W. S. ATKINS &amp; PARTNERS OVERSEAS</b> <b>PROJECT : GOLD CREST RESIDENTIAL TOWER</b>	<b>HMR 819</b>
--	----------------

<b>To</b> : Bautech International (LLC)	<b>Location</b> : <u>Dubai</u>
<b>Attention</b> : Mr. Mohiydeen Shanabliih	
<b>Fax No.</b> : 2683888	
<b>Transmittal No.</b> : 6.2/486	

Attached is a Original/Copy of the following document/drawing with Consultant's comment for your :

**Action**
                 
  **Comments**
                 
  **Information**
                 
  **Record**

**DOCUMENT** : \_\_\_\_\_ **Ref.** : \_\_\_\_\_

1) Technical Submittal No. HMR-819-S-TS-087 Rev. 0 (Pre-qualification for threaded couplers)

**NOTES** :

<b>Signature</b> : _____ <i>pp</i> HMR 819	<b>Date</b> : <u>15-May-05</u>
---	--------------------------------

Please acknowledge receipt of the documents listed above by signing, and returning this sheet to the originator. Should any of the above items be a revision to that already received, it is your responsibility to ensure that the earlier edition is removed from circulation.

I acknowledge receipt of the document(s) indicated above.

<b>Signature</b> : _____	<b>Date:</b> _____
Received	

**Please return acknowledgment to**

Ibrahim Heyasat  
Project Manager (HMR-819)

**SITE HMR - 819**  
**16 MAY 2005**  
**FAXED**